| Laboratory | GE T&D India Limited, Laboratory, Plot No. 46, SIPCOT Industrial Complex, Zuzuwadi Village, Hosur, Tamil Nadu | | |
|------------------------|---|-----------------|--|
| Accreditation Standard | ISO/IEC 17025: 2005 | | |
| Certificate Number | TC-6923 | Page 1 of 4 | |
| Validity | 20.02.2018 to 19.02.2020 | Last Amended on | |

| SI. | Product / Material | Specific Test | Test Method Specification | Range of Testing / |
|-----|--------------------|---------------|----------------------------------|---------------------|
| | of Test | Performed | against which tests are | Limits of Detection |
| | | | performed | |

ELECTRICAL TESTING

| ١. | TRANSMISSION L | | | |
|----|-------------------------|--|---|---|
| 1. | Current Transformers | Verification of Terminal marking Polarity | IS 2705 (Part 1): 1992 (RA 2017) | Qualitative |
| | Upto 765 kV | Power Frequency voltage withstand Inter-turn overvoltage Winding Resistance | IS 2705 (Part 4): 1992 (RA 2007) IEC 61869-1 (2012) IEC 61869-2 (2012) | 5 kV to 1000 kV 1.5 kV to 5 kV 1 kVp to 10 kVp 0 5 0 to 2000 0 |
| | | Knee point voltage and current | | 1 kV to 6.6 kV 1 A to 10 A |
| | | Composite Error (Secondary method) | | 1 kV to 6.6 kV 1 A to 10 A |
| | | Instrument Security Factor (Secondary method) | | 300 V and 10 A 25 V and 1 A |
| | | Accuracy (Ratio & Phase angle measurement, TRE) | | Upto 200 % Upto 100 VA |
| | | Partial discharge | | Upto 50 pC |
| | | Capacitance Tan delta | | 25 pF to 110 μF 0.5× 10 ⁻³ to 5× 10 ⁻³ |
| | | Temperature rise | | 20 °C to 100 °C Up to 4800 A |
| | | Corona inception & Extinction (Dry) Visual Corona | IS 2071 (2016) | 40 kV to 650 kV |
| | | Thermal stability | AS 1675 (1986) | Up to 4800 A 20 °C to 100 °C 5 kV to 1000 kV |
| | | Lightning Impulse | IEC 60060-1 (2010) IEC 61869-1 (2012) | 300 kVp to 2700 kVp |

Laboratory GE T&D India Limited, Laboratory, Plot No. 46, SIPCOT Industrial Complex, Zuzuwadi Village, Hosur, Tamil Nadu

| Accreditation Standard | I ISO/IEC 17025: 2005 | | |
|------------------------|--------------------------|-----------------|--|
| Certificate Number | TC-6923 | Page 2 of 4 | |
| Validity | 20.02.2018 to 19.02.2020 | Last Amended on | |

| SI. | Product / Material of Test | Specific Test Performed | Test Method Specification against which tests are | Range of Testing / Limits of Detection |
|-----------------------|-------------------------------|---|---|--|
| l | | <u> </u> | performed | <u> </u> |
| | | Lightning Impulse Chopping | IEC 61869-2 (2012) | 300 kVp to 2400 kVp |
| | | Switching Impulse | | 500 kVp to 1500 kVp |
| 2. | Capacitive Voltage | Capacitance Tan Delta | IEC 60358 (2005) IEC 60044-5 (2004) | 10 pF to 110 μF 0.5× 1 |
| Transform Coupling | Transformers & Coupling | Verification of Terminal markings & polarity. | IEC 61869-5 (2011) | Qualitative |
| | Capacitors Up to 765 kV | Power Frequency voltage withstand (Dry) | | 5 kV to 1000 kV 1.5 kV to 5 kV |
| | | Accuracy (Ratio & Phase angle) | | RE Up to ± 6 % PE Up to ± 130' Burden 1.25VA to 584VA 0.8 lag |
| | | Partial discharge | | Upto 50pC |
| | | Corona inception & Extinction test (Dry) Visual Corona | | 40 kV to 550 kV |
| | | Ferro resonance | | 5 kV to 220 kV |
| | | Transient Response | | 2 kV to 17 kV |
| | | Stray Capacitance & Stray conductance | | Up to 1000 pF Up to 400 μs |
| | | High Frequency capacitance & series Resistance | | Upto 1.1 μF 100 Ω |
| | | Short circuit withstand capability | | 2 kV to 220 kV |
| | | Temperature rise | | 20 °C to 100 °C |
| | | Temperature co- efficient | | (-) 5 °C to 100 °C 25 pF to 110µF |
| | | Induced Over voltage | | 2 kV to 140 kV |
| | | Tightness of the liquid- filled capacitor voltage divider | IEC 60044-5(2004) | 0.5 kg/cm ² to 2 kg/cm ² |

| Laboratory | GE T&D India Limited, Laboratory, Complex, Zuzuwadi Village, Hosur, | E T&D India Limited, Laboratory, Plot No. 46, SIPCOT Industrial omplex, Zuzuwadi Village, Hosur, Tamil Nadu | |
|------------------------|--|---|--|
| Accreditation Standard | ISO/IEC 17025: 2005 | | |
| Certificate Number | TC-6923 | Page 3 of 4 | |

Validity 20.02.2018 to 19.02.2020

Last Amended on --

| SI. | Product / Material of Test | Specific Test Performed | Test Method Specification against which tests are performed | Range of Testing / Limits of Detection |
|-----|-------------------------------|--|---|---|
| | | Lightning Impulse test | IEC 60060-1 2010 | 300 kVp to 2700 kVp |
| | | Chopping Impulse test | IEC 60044-1 2003 | 300 kVp to 2400 kVp |
| | | Switching Impulse test | IEC 61869-1 2012 IEC 61869-2 2012 | 500 kVp to 1500 kVp |
| 3. | Line Traps Up to 765 kV | Blocking resistance & Blocking Impedance | IEC 60353 (2002) | 10 Ω to 2000 Ω |
| | | Tapping loss and Tapping loss based on resistance | | 0.5 dB to 3 dB |
| | | Power frequency voltage on Tuning device | | 2 kV to 21 kV |
| | | Rated Inductance of the main coil | | 0.1 mH to 2 mH |
| | | Power frequency Inductance of the main coil | | 0.1 mH to 2 mH |
| | | Temperature rise | | Up to 3200 A Up to 150 °C |
| | | Winding resistance | | $2 \text{ m}\Omega$ to $15 \text{ m}\Omega$ |
| | | Corona inception & Extinction test (Dry) Visual Corona | IS 2071 (2016) | 40 kV to 650 kV |
| | | Lightning Impulse | IEC 60060-1 IEC 60353 (2002) | 20 kVp to 150 kVp |
| 4. | Bushings Up to 420 kV | Capacitance Tan Delta | IS 2099: 1992 (RA 2008) IEC 60137 (2008) | 10 pF to 110μF 0.5× 10 ⁻³ to 5× 10 ⁻³ at 630 kV |
| | | Power Frequency voltage withstand | | 2 kV to 1000 kV |
| | | Partial discharge | 4 | Up to 50pC |
| | | Temperature rise | | 20 °C to 150 °C |
| | | Thermal stability | | 1 A to 10 A 50 A to 3160 A |

| Laboratory | GE T&D India Limited, Laboratory, Plot No. 46, SIPCOT Industrial Complex, Zuzuwadi Village, Hosur, Tamil Nadu | |
|------------------------|--|-------------|
| Accreditation Standard | ISO/IEC 17025: 2005 | |
| Certificate Number | TC-6923 | Page 4 of 4 |

Last Amended on --

Validity 20.02.2018 to 19.02.2020

| SI. | Product / Material of Test | Specific Test Performed | Test Method Specification against which tests are performed | Range of Testing / Limits of Detection |
|-----|-------------------------------|---|---|--|
| | | | | 25 pF to 110 pF 10 °C to 150 °C 0.5× 10 ⁻³ to 5× 10 ⁻³ |
| | | Tightness | | 0.5 kg/cm ² to 2 kg/cm ² |
| | | Lightning impulse | IEC 60060-1 IEC 60137(2008) | 300 kVp to 2700 kVp |
| | | Switching impulse | IEC 60060-1 IEC 60137(2008) | 500 kVp to 1500 kVp |
| | | Chopping Impulse | IEC 60060-1 IEC 60137(2008) | 300 kVp to 2400 kVp |
| 11. | ELECTRICAL MATE | ERIALS – LIQUID DIELEC | TRIC MATERIALS | |
| 1. | Insulating Oils | Electric Strength (Break Down Voltage) | IEC 60156: 1995 IS 6792 (1992) | Up to 100 kV |
| | | Specific Resistance | IS 6103 (1971) | 10 ⁶ to 10 ¹⁶ Ω |
| | | Dielectric dissipation factor (Tan ^ō at 90/100°C) | IS 6262 (1971) | 0.0001 to 0.1 |
| | | Inter facial Tension at 27 °C | IS 6104 (1971) | 0.01 N/m to 0.18 N/m |
| | | Water Content | IS 13567 (1992) | 2 mg/l to 100 mg/l 2 ppm to 100 ppm |
| | | Dissolved Gas Analysis Carbon Dioxide (CO ₂) Carbon Monoxide (CO) Acetylene(C ₂ H ₂) Ethylene (C ₂ H ₄) Ethane (C ₂ H ₆) Methane (CH ₄) Hydrogen (H ₂) | IEC 60599:1999 IEC 60567:2011 | 1 ml/l to 2500 ml/l 1 ppm to 2500 ppm |
| | | Particle Count | ISO 11171:2016 | 1 micron to 100 microns |