

**Laboratory** Sreeja Electricals, Transformer Oil Testing Lab, Plot No. S-122, Phase-III, Verna Industrial Estate, Verna, Goa

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Electrical Testing **Issue Date** 31.07.2015

**Certificate Number** T-2501 **Valid Until** 30.07.2017

**Last Amended on** - **Page** 1 of 1

S.No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
<b>I. ELECTRICAL MATERIALS - LIQUID DIELECTRIC MATERIALS</b>				
1.	<b>Transformer Oil</b>	Interfacial Tension Test	IS 6104: 1971	0 to 90 mN/m
		Flash Point	IS 1448 (P:21)1992	27 °C to 170 °C
		Neutralization Value	IS 1448 (P:2) 2007	0 to 1 mg of KOH/g
		Breakdown Voltage	IS 6792:1992 RA 2003	2 kV to 100 kV
		Dielectric Dissipation Factor	IS 6262: 1971 RA 2001	0.00001 to 10
		Specific Resistance	IS 6103: 1971 RA 2001	10 <sup>7</sup> Ω-cm to 10 <sup>15</sup> Ω-cm
		Water Content	IS 13567: 1992	4 mg/kg to 1000 mg/kg
		Sludge (%)	IS 1866: 2000 Annexure "A"	0 to 2 %
		Dissolved Gas Analysis	IS 9434: 1992 & IS:10593: 2006	
		CO		10 ml/l to 1000 ml/l
		CH <sub>4</sub>		1 ml/l to 4000 ml/l
		CO <sub>2</sub>		10 ml/l to 10000 ml/l
		C <sub>2</sub> H <sub>4</sub>		1 ml/l to 4000 ml/l
		C <sub>2</sub> H <sub>6</sub>		1 ml/l to 4000 ml/l
		C <sub>2</sub> H <sub>2</sub>		1 ml/l to 4000 ml/l
		H <sub>2</sub>		10 ml/l to 1000 ml/l
		N <sub>2</sub>		25 ml/l to 200000 ml/l
		O <sub>2</sub>		25 ml/l to 100000 ml/l

~~-X-X-X-X-X-X-X-X-X-X-X-X-~~

**Rajeshwar Kumar**  
Convenor

**N. Venkateswaran**  
Program Manager