

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>1 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT LABORATORY**

**I. PERFORMANCE TEST**

<b>1.</b>	<b>Dry Chemical Powders for Fighting B &amp; C Class fires</b>	Free Flowing Characteristics Foam Compatibility Fire Knocking down for Class B fires	IS 4308 : 2003 CL.- 4.10 CL. - 4.11 CL. - 4.12	0 to100 g/s Qualitative Qualitative
<b>2.</b>	<b>Dry Chemical Powders for fighting A,B,C Class fires</b>	Free Flowing Characteristics Foam Compatibility Fire Knocking down For Class A fires Fire Knocking down For Class B fires	IS 14609 : 1999 CL. - 4.10 CL. - 4.11 CL. - 4.12.1 CL. - 4.12.2	0 to100 g/s Qualitative Qualitative Qualitative
<b>3.</b>	<b>Dry Powder for Fighting Fires in Burning metals</b>	Free flowing Characteristics Fire Extinguishment Test	IS 4861 : 1984 CL. - 2.5 CL. - 2.7	Qualitative Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>2 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
<b>4.</b>	<b>Dry Chemical Fire Extinguisher</b>	General Pressure build up test	UL 299 : 2009	Qualitative
		Locking device	CL. - 23.1	Upto 500 N
	<b>Capacity(Water capacity) ;-</b>	<b>Handle &amp; mounting</b>	CL. - 25	Qualitative
	4.5, 9.0, 14.0, 18.0, 36.0, 64.0, 125.0 l	- Static load test	CL. - 26	Qualitative
		- Force required to open the bracket	CL. - 26.1 & 26.2	Upto 500 N
			CL. - 26.3	
		Operation Test	CL. - 27	Qualitative
		Discharge Duration Test	CL. - 28	Upto 3 min
		Rate of Flow Test	CL. - 29	0 to 100 %
		Discharge Range	CL. - 30	Upto 5 mt
		Intermittent Discharge	CL. - 31	0 to 100 %
		Operating temperature limits test	CL. - 32	0 to 100 %
		Temperature cycling test	CL. - 33	0 to 100 %
		30 Day elevated temperature exposure test	CL. - 34	0 to 100 %
		High temperature exposure test	CL. - 35	Qualitative
		Abnormal operation test	CL. - 36	0 to 100 %

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>3 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Dry Chemical Fire Extinguisher Capacity (Water capacity) :- 4.5, 9.0, 14.0, 18.0, 36.0, 64.0, 125.0 l</b>	Pressure – retention test	CL. - 37	Qualitative
		Packed Chamber test	CL. - 38	0 to100 %
		Packed Hose test	CL. - 39	Upto 300 s
		Hydrostatic pressure test	CL. - 40	Qualitative
		Discharge valve (HPT)	CL. - 40.2	Qualitative
		Hose Assemblies (HPT)	CL. - 40.3	Qualitative
		Gas cartridges (HPT)	CL. - 40.4	Qualitative
		Vibration test	CL. – 41	Qualitative
		Mounting of test sample	CL. - 41.2 to 41.5	Qualitative
<b>5.</b>	<b>Portable Fire Extinguishers – Performance &amp; construction Capacity :-a)Water base : 2,6,9 l b)Foam : 2,4,6,9 l c) Dry Powder : 1,2,4,6,9 l d) CO<sub>2</sub> : 2,3,4.5 kg e) Clean Agent 2,4,6 kg</b>		IS 15683 : 2006	
		Service Pressure (Ps)	CL. - 3.5 & 9.2.1.1	Upto 100 bar
		Maximum service pressure (Pms)	CL. - 3.6	Upto 150 bar
		Fill density	CL. - 5.3.1	Upto 2 kg/l
		Filling Tolerance	CL. - 5.3.2	Upto (±) 25 %
		Test pressure	CL. - 6.1	Upto 100 bar
		Minimum Burst pressure	CL. - 6.2	Upto 260 bar

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>4 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Portable Fire Extinguishers – Performance &amp; construction Capacity :-</b> <b>a)Water base : 2,6,9 l</b> <b>b)Foam : 2,4,6,9 l</b> <b>c) Dry Powder : 1,2,4,6,9 l</b> <b>d) CO<sub>2</sub> : 2,3,4.5 kg</b> <b>e) Clean Agent 2,4,6 kg</b>	Minimum effective discharge time for Class A rated Extinguishers	CL. - 7.2.1	Upto 120 s
		Minimum effective discharge time for Class B rated Extinguishers	CL. - 7.2.2	Upto 120 s
		Bulk Range Throw	CL. - 7.2.3	Upto 15 m
		Resistance to temperature changes	CL. - 7.3	(+) 80°C to (-) 30°C & retention Upto100%
		Retention of charge following partial discharge	CL. - 7.4.2	Upto 100 %
		leakage Test	CL. - 7.4.3	Qualitative
		Resistance to Impact (Mechanical resistance)	CL. - 7.5.1	Qualitative
		Resistance to Vibration's	CL. - 7.5.2	Qualitative
		External Corrosion Test	CL. - 7.6.1	Qualitative
		Internal Corrosion Test Tapping Test	CL. - 7.6.2 CL. - 7.7	Qualitative 0 to 100 %
	Intermittent Discharge test	CL. - 7.8	Upto 100 %	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>5 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Portable Fire Extinguishers – Performance &amp; construction Capacity :-</b> <b>a)Water base : 2,6,9 l</b> <b>b)Foam : 2,4,6,9 l</b> <b>c) Dry Powder : 1,2,4,6,9 l</b> <b>d) CO<sub>2</sub> : 2,3,4.5 kg</b> <b>e) Clean Agent 2,4,6 kg</b>	Construction Requirements of High-Pressure Extinguishers	CL - 9.1	Upto 200 bar
		Service Pressure	CL - 9.2.1.1	Upto 100 bar
		Construction (service pressure test)	CL - 9.2.1.2	Upto 200 bar
		Requirement of welding	CL - 9.2.1.3	Qualitative
		Construction (test of stress & corrosion)	CL - 9.2.1.4	Qualitative
		Thread of Plastic components (No. of thread per cm)	CL - 9.2.1.6	Upto 10 No /cm
		Construction (test of pressure retaining part of the body)	CL - 9.2.1.7	Upto 25 mm
		Burst test	CL - 9.2.2.1 to 9.2.2.6	Upto 260 bar
		Crushing Test	CL - 9.2.3	Upto 260 bar
		Pressure cycling test	CL - 9.2.5	Upto 100 bar
	Measured thickness of the cylinder	CL - 9.2.6.3	Upto 25 mm	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>6 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Portable Fire Extinguishers – Performance &amp; construction Capacity :-</b> <b>a)Water base : 2,6,9 l</b> <b>b)Foam : 2,4,6,9 l</b> <b>c) Dry Powder : 1,2,4,6,9 l</b> <b>d) CO<sub>2</sub> : 2,3,4.5 kg</b> <b>e) Clean Agent 2,4,6 kg</b>	Carrying handle test	CL - 9.3.1	Qualitative
		Requirement of Handle length	CL - 9.3.2	Upto 0.5 m
		Requirement of handle clearance	CL - 9.3.3	Upto 0.5 m
		Mounting test	CL-9.4.1	Qualitative
		Requirement of mounting hook	CL-9.4.2	Qualitative
		Requirement of mounting bracket	CL - 9.4.3 & 9.4.4	Qualitative
		Requirement of strap	CL - 9.4.5	Qualitative
		Requirement of hanger loop	CL - 9.4.6	Qualitative
		Claps, valves & Closure	CL - 9.5.1	Qualitative
		Requirement of threaded connections on cylinder (No. of full thread)	CL - 9.5.2	Upto 30 nos.
		Requirement of filling opening	CL - 9.5.3	Upto 100 mm
		Requirement of collar	CL - 9.5.4	Qualitative
		Requirement of burst test of cap, valve, & closure	CL - 9.5.5	Upto 250 bar

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>7 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Portable Fire Extinguishers – Performance &amp; construction Capacity :-</b> a)Water base : 2,6,9 l b)Foam : 2,4,6,9 l c) Dry Powder : 1,2,4,6,9 l d) CO <sub>2</sub> : 2,3,4.5 kg e) Clean Agent 2,4,6 kg	Requirement of edges& surfaces	CL - 9.5.6	Qualitative
		Requirement of hose assemblies	CL - 9.9.1	Qualitative
		Requirement of hose & coupling system	CL - 9.9.2	Qualitative
		Requirement of burst pressure of hose assemblies	CL - 9.9.3	Upto 260 bar
		Requirement of withstanding hydrostatic pressure of hose assemblies	CL - 9.9.4	Upto 100 bar
		Method of Operation	CL - 9.10	Upto 500 N
		Safety locking device	CL - 9.11&9.11.1	Upto 500 N
		Requirement of safety device material	CL - 9.11.2	Qualitative
		a. Requirement of safety-locking pin or other device	a.CL - 9.11.3, 9.11.4, 9.11.5	a. Qualitative
		b. Force required for breaking the tamper indicator	b. CL - 9.11.6	b. Upto 500 N
	Requirement of Dip-Tubes & Filters	CL - 9.13	Upto 5 mm	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>8 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
		Special Requirement for CO <sub>2</sub> Extinguishers	CL - 9.14	Qualitative
		Colour test (Shade Test)	CL - 10.1	Qualitative
<b>6</b>	<b>Fire fighting portable fire extinguishers- Performance and construction Capacity :-</b>	Service Pressure (Ps)	ISO 7165 : 2009 CL - 3.20 & 9.2.1.1	Upto 100 bar
	<b>a)Water base ;</b>	Maximum service pressure (Pms)	CL - 3.14	Upto 150 bar
	<b>2,3,6,9 l</b>	Fill density	CL - 5.3.1	Upto 2 kg/l
	<b>b)Powder ;</b>	Filling Tolerance	CL - 5.3.2	Upto (±)25%
	<b>1,2,3,4,6,9,12 kg</b>	Test pressure	CL - 6.1	Upto 100 bar
	<b>c) CO<sub>2</sub> ;</b>	Minimum Burst pressure	CL - 6.2	Upto 260 bar
	<b>2,5 kg</b>	Minimum effective discharge time for Class A rated Extinguishers	CL - 7.2.1	Upto 120 s
	<b>d)Clean agent :</b>			
	<b>1,2,4,6 kg</b>			



<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>9 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Fire fighting portable fire extinguishers- Performance and construction Capacity :-</b> <b>a)Water base ; 2,3,6,9 l</b> <b>b)Powder ; 1,2,3,4,6,9,12 kg</b> <b>c) CO<sub>2</sub> ; 2,5 kg</b> <b>d)Clean agent : 1,2,4,6 kg</b>	Minimum effective discharge time for Class B rated Extinguishers	CL - 7.2.2	Upto 120 s
		Bulk Range Throw	CL - 7.2.3	Upto 15 m
		Resistance to temperature changes	CL - 7.3	(+) 80°C to (-) 30°C & retention Upto 100 %
		Retention of charge following partial discharge	CL - 7.4.2	Upto 100 %
		Long term leakage Test	CL - 7.4.3	Upto 100 %
		Resistance to Impact (Mechanical resistance)	CL - 7.5.1	Qualitative
		Resistance to Vibration's	CL - 7.5.2	Qualitative
		External Corrosion Test	CL - 7.6.1	Qualitative
		Internal Corrosion Test	CL - 7.6.2	Qualitative
		Tapping Test	CL - 7.7	Upto 100 %
	Intermittent Discharge test	CL - 7.8	Upto 100 %	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>10 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Fire fighting portable fire extinguishers- Performance and construction Capacity :- a)Water base ; 2,3,6,9 l b)Powder ; 1,2,3,4,6,9,12 kg c) CO<sub>2</sub> ; 2,5 kg d)Clean agent : 1,2,4,6 kg</b>	Construction (Requirements of High-Pressure Extinguishers) Service Pressure	CL - 9.1 CL - 9.2..1.1	Qualitative Upto 100 bar
		Test of vertical stand	CL - 9.2.1.2	Qualitative
		Requirement of welding	CL - 9.2.1.3	Qualitative
		Construction (design)	CL - 9.2.1.4	Qualitative
		Thread of Plastic components (No. of thread per cm)	CL - 9.2.1.6	Upto 10 Nos/cm
		Construction (pressure retention part)	CL - 9.2.1.7	Qualitative
		Burst test	CL - 9.2.2	Upto 260 bar
		Crushing Test	CL-9.2.3	Upto 260 bar
		Measured thickness of the cylinder	CL-9.2.5.3,9.2.6 &9.2.7	Upto 25 mm
		Carrying handle	CL-9.3.1	Qualitative
		Requirement of Handle length	CL-9.3.2	Upto 0.5 m
		Requirement of handle clearance	CL-9.3.3	Upto 0.5 m

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>11 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Fire fighting portable fire extinguishers- Performance and construction Capacity :- a)Water base ; 2,3,6,9 l b)Powder ; 1,2,3,4,6,9,12 kg c) CO<sub>2</sub> ; 2,5 kg d)Clean agent : 1,2,4,6 kg</b>	Mounting	CL-9.4.1	Qualitative
		Requirement of mounting hook	CL-9.4.2	Qualitative
		Requirement of mounting bracket	CL-9.4.3&9.4.4	Qualitative
		Requirement of strap	CL-9.4.5	Qualitative
		Requirement of hanger loop	CL-9.4.6	Qualitative
		Claps, valves & Closure test	CL-9.5.1	Upto 10 mm
		Requirement of threaded connections on cylinder (No. of full thread)	CL-9.5.2	Upto 30 Nos.
		Requirement of filling opening	CL-9.5.3	Upto 100 mm
		Requirement of collar	CL-9.5.4	Qualitative
		Requirement of burst test of cap, valve & closure	CL-9.5.5	Upto 260 bar
	Requirement of edges & surfaces	CL-9.5.6	Qualitative	
	Requirement of hose assemblies	CL-9.9 & 9.9.1	Qualitative	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>12 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
		Requirement of hose & coupling system	CL-9.9.2	Qualitative
		Requirement of burst pressure of hose assemblies	CL - 9.9.3	Upto 260 bar
		Requirement of withstanding hydrostatic pressure of hose assemblies	CL - 9.9.4	Upto 100 bar
		Method of Operation	CL - 9.10	Upto 500 N
		Safety locking device	CL - 9.11.1	Upto 500 N
		Requirement of safety device material	CL - 9.11.2	Qualitative
		Requirement of safety-locking pin or other device	CL - 9.11.3, 9.11.4, 9.11.5	Qualitative
		Force required for breaking the tamper indicator	CL - 9.11.6	Upto 500 N
		Requirement of Dip-Tubes & Filters	CL - 9.13	Upto 5 mm
		Special Requirement for CO <sub>2</sub> Extinguishers	CL - 9.14	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>13 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
7.	<b>Wheeled fire Extinguishers – Performance &amp; Construction Capacity :-</b>		<b>IS 16018: 2012</b>	
	<b>a)Water base ; 20,45,60, 125 l</b>	Maximum service pressure (Pms)	CL-3.16	Upto 260 bar
	<b>b)Powder ; 25,50,75 kg</b>	Service Pressure (Ps)	CL-3.19	Upto 260 bar
	<b>c)Clean agent ; 10,20,30,50 kg</b>	Test Pressure	CL-3.20	Upto 260 bar
	<b>d) CO2 ; 4.5,6.5,22.5,45 kg</b>	Fill density	CL-5.3	Upto 2 kg/l
		Filling Tolerance	CL-5.4	Upto (±)25%
		Effective discharge time	CL - 6.2.1.1, 6.2.1.2, 6.2.1.3	Upto 240 s
		Bulk Range Throw	CL-6.2.2	Upto 15 m
		Resistance to temperature changes	CL-6.3	Ambient to 80 °C & Ambient to (-) 30 °C
		Retention of charge	CL-6.4	Upto 100 %
		Intermittent Discharge test	CL-6.5	Upto 100 %
		External Corrosion Test	CL-6.6.1	Qualitative
		Internal Corrosion Test	CL-6.6.2	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>14 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Wheeled fire Extinguishers – Performance &amp; Construction Capacity :- a)Water base ; 20,45,60, 125 l b)Powder ; 25,50,75 kg c)Clean agent ; 10,20,30,50 kg d) CO2 ; 4.5,6.5,22.5,45 kg</b>	Service Pressure	CL - 8.1.1	Upto 100 bar
		Requirement of welding	CL - 8.1.3	Qualitative
		Part attached to the body of the cylinder(test of stress & corrosion)	CL - 8.1.4	Qualitative
		Thread of Plastic components (type of thread)	CL - 8.1.6	Qualitative
		High Pressure Extinguisher (Ps test)	CL - 8.2	Upto 200 bar
		Low Pressure extinguisher (Ps test)	CL- 8.3	Upto 200 bar
		Burst Test	CL - 8.3.1	Upto 260 bar
		Deformation Test	CL - 8.3.2	Upto 260 bar
		Pressure Cycling test	CL - 8.3.3	Upto 260 bar
		Minimum wall thickness	CL-8.6	Upto 25 mm
	Claps, valves& Closure test	CL - 8.7.1	Qualitative	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>15 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Wheeled fire Extinguishers – Performance &amp; Construction Capacity :-</b> <b>a)Water base ; 20,45,60, 125 l</b> <b>b)Powder ; 25,50,75 kg</b> <b>c)Clean agent ; 10,20,30,50 kg</b> <b>d) CO2 ; 4.5,6.5,22.5,45 kg</b>	Requirement of threaded connections on cylinder (No. of thread per cm)	CL - 8.7.2	Upto 10 Nos./cm
		Requirement of filling opening	CL - 8.7.3	Upto 100 mm
		Requirement of collar	CL - 8.7.4	Qualitative
		Requirement of burst test of cap, valve & closure	CL - 8.7.5	Upto 260 bar
		Requirement of edges& surfaces	CL - 8.7.6	Qualitative
		Safety and Anti-overfill device test	CL - 8.8	Qualitative
		Discharge Assembly (Requirement of Hose)	CL - 8.11.1	Qualitative
		Hose & Coupling system	CL - 8.11.2	Qualitative
		Burst Pressure of Hose	CL - 8.11.3	Upto 260 bar
		Control valve (leakage test)	CL - 8.12	Qualitative
		Horn for Carbon dioxide	CL - 8.13	Qualitative
		Method of Operation	CL - 8.14	Upto 500 N

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>16 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
		Safety locking device	CL - 8.15	Upto 500 N
		Dip tubes and filters for water based extinguisher	CL - 8.17	Upto 10 mm
		Carriage assembly (Mobility test)	CL - 8.18.1 & 8.18.2	Upto 500 N
		Hose Retaining unit	CL-8.18.3	Qualitative
		Colour test	CL-9.1	Qualitative
<b>8.</b>	<b>Portable Fire Extinguishers Part-7, Characteristics performance measurements &amp; test method capacity:-Powder; 1,2,3,4,6,9,12 kg Water base; 2,3,6,9 l CO<sub>2</sub> ; 2, 5 kg Halon ; 1,2,4,6 kg</b>	Control of Discharge	EN : 3 7 : 2007-10 CL - 4.2	Qualitative
		Operating position	CL - 4.3	Qualitative
		Hose Assembly	CL - 4.4	Qualitative
		Stored pressure extinguisher	CL - 4.6	Qualitative
		Nominal charge test	CL - 6.1	0 to 30 kg
		Filling Tolerance	CL - 6.2	Upto (±) 25 %
		Duration of operation, minimum duration, spread measurement	CL - 7.1.1 & 7.1.2	Upto 120 s & throw Upto 10 m
		Residual charge	CL - 7.2	Upto 50 %



<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>17 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Portable Fire Extinguishers Part-7, Characteristics performance measurements &amp; test method capacity:-Powder; 1,2,3,4,6,9,12 kg Water base; 2,3,6,9 l CO<sub>2</sub> ; 2, 5 kg Halon ; 1,2,4,6 kg</b>	Commencement of discharge	CL - 7.3	0 to 10 s
		Effective range of operating temperature	CL - 7.4	Upto 180 s
		General requirement (Operating mechanism)	CL-10.1	Upto 500 N
		Operation & Emission control mechanism / devices	CL-10.2	Upto 500 N
		Safety Devices	CL-10.3	Upto 500 N
		Filter for water based portable fire extinguisher	CL-10.4	0 to 25 mm
		Hose & Coupling system (HPT)	CL-10.5	Upto 100 bar
		Control valve (leakage test)	CL-10.6	Upto 100 %
		Horns for Carbon dioxide Portable fire extinguishers (Deformation test)	CL-12	0 to 25 mm
		Portable fire extinguisher Mounting Bracket (load test)	CL-13	Qualitative
	Resistance to External Corrosion test	CL-14.1	Qualitative	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>18 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
		Resistance to extinguishing medium of extinguisher using water based media	CL-14.2	Qualitative
<b>9.</b>	<b>Mobile Fire Extinguishers – Part-1:characteristics Performance and test methods Capacity:- Powder;- 25,50,100,150kg Water base ;- 20,25,45,50, 90,100,135, 150 l CO2 ;- 10, 20, 30, 50 kg</b>	Effective range of time of operating temperatures	DINEN 1866-1 : 2007-10 CL - 6.1	Upto 180 s
		Filling Tolerance	CL - 6.2.2	Upto 25 %
		Duration of operation	CL - 6.3.1	Upto 240 s
		Maximum residual mass	CL - 6.3.2	Upto 100 %
		Control value (P.leak test)	CL - 6.5	Upto 100 %
		Working position (Hose pull test)	CL - 6.6	Upto 500 N
		Hose and Coupling	CL - 6.7	Upto 10 m
		Operating and jet control mechanism devices	CL - 6.8.2	Upto 500 N
		Safety devices	CL - 6.8.3	Upto 500 N
		Discharge from water based extinguishers(orifice test)	CL - 6.8.4	0 to 25 mm

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>19 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Mobile Fire Extinguishers – Part-1: characteristics Performance and test methods Capacity:- Powder;- 25,50,100,150kg Water base ;- 20,25,45,50, 90,100,135, 150 l CO2 ;- 10, 20, 30, 50 kg</b>	Design of the filling opening	CL - 6.8.6.1	Qualitative
		Diameter of the two wheels	CL - 6.8.6.2	Upto 300 mm
		Width of the tyres	CL - 6.8.6.3	Upto 300 mm
		Distance between the handle and the floor	CL - 6.8.6.4	Upto 2 m
		Socket for the Nozzle	CL - 6.8.6.5	Qualitative
		Damage of the Hose	CL - 6.8.6.6	Qualitative
		Temperature Test	CL - 7.1	Qualitative
		External Corrosion Test	CL - 7.2.1	Qualitative
	Internal Corrosion Test for water based extinguishers	CL - 7.2.2	Qualitative	

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>20 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
<b>10.</b>	<b>For Non-Percolating Flexible Fire Fighting Delivery Hose</b>	Workmanship (Def. test)	IS 636 : 1988 CL - 5.1.1.1	Qualitative
		Internal Diameter	CL - 5.2	Upto 100 mm
		Length	CL - 5.3	Upto 50 m
		Mass	CL - 5.4	Upto 300 kg
		Coil Diameter	CL-5.5	Upto 5 m
		Hydrostatic Burst Pressure test	CL-5.6	Upto 100 bar
		Hydrostatic Proof Pressure test	CL-5.7	Upto 100 bar
		Kink test	CL-5.8	Upto 100 bar
		Change in length	CL-5.9	Upto 100 mm
		Change in Diameter	CL-5.10	Upto 100 mm
		Requirement for Rubber lining and the outer coating, adhesion test	CL-5.11.1	Upto 100 mm/min
		Accelerated Ageing test	CL-5.11..2	Upto 100 mm/min
Abrasion Resistance	CL-5.12	Upto 500 cycle		

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>21 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
		Water Pick up / Moisture Absorption (for type B only)	CL-5.13	Upto 1 kg/m <sup>2</sup>
		Heat Resistance	CL-5.14	Upto 80°C
		Oil Resistance test (for type B only)	CL-5.15	Upto 80°C
<b>11.</b>	<b>Controlled Percolating Hose For Fire Fighting – Specification</b>	Diameter	IS 8423 : 1994 CL - 4.1&4.1.1	Upto 100 mm
		Length	CL - 5.1	Upto 50 m
		Coil Diameter (Machine coiled)	CL - 6.1	Upto 5 m
		Mass	CL - 7.1	Upto 300 kg
		Percolation	CL - 8.1	Upto 20 kg/ltr.
		Evenness of wetting out	CL-9.1	Upto 100 kg/cm <sup>2</sup>
		Hydrostatic Proof Pressure	CL-10.1	Upto 100 kg/cm <sup>2</sup>
		Hydrostatic Bursting Pressure	CL-11.1	Upto 100 kg/cm <sup>2</sup>
		Flammability	CL-12.1	Upto 100 kg/cm <sup>2</sup>
		Kink test	CL-13.1	Upto 100 kg/cm <sup>2</sup>
		Change in size	14.1	Upto 100 mm

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>22 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
12.	<b>Thermoplastic Hoses (Textile Reinforced) For Water – General Purpose</b>	Requirements (Physical test of lining, reinforcement & Cover)	IS 12585 : 1988 CL-4.1	Qualitative
		Dimensions and Tolerances	CL-4.2	Upto 15 m
		Loss in Mass on Heating	CL-4.3.1	Upto 20 %
		Adhesion	CL-4.3.2	Upto 20 KN/m
		Pressure requirements	CL-4.3.3	Upto 100 kg/cm <sup>2</sup>
		Minimum Bend Radius	CL-4.3.4	Qualitative
		Low temperature flexibility	CL-4.3.5	500 mm
13.	<b>Unlined Flax Canvas Hose Fire Fighting</b>	Material (Alkali solubility test of Flex yarn)	IS 4927 : 1992 CL - 3	Qualitative
		Size	CL-4.1	Upto 100 mm
		Tolerances on Internal Diameter	CL-4.2	Upto 100 mm
		Length	CL-5	Upto 50 m
		Mass	CL-6	Upto 20 kg
		Flexibility(Coil dia)	CL-7	Upto 5 m

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>23 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
		Percolation	CL-8	Upto 20 l
		Change in length & Change in Diameter	CL-9.1 & 9.2	Upto 5 m
		Hydrostatic proof pressure	CL-10	Upto 100 kg/cm <sup>2</sup>
		Hydrostatic burst pressure tests	CL-11	Upto 100 kg/cm <sup>2</sup>
<b>14.</b>	<b>Landing valves</b>	Types & Dimension	IS 5290 : 1993 CL - 5	Upto 100 mm
		Water tightness test for the Valve	CL - 7.1	Upto 300 bar
		Hydrostatic Pressure test	CL - 7.2	Upto 100 bar
<b>15.</b>	<b>Fireman's Axe</b>	Shape, Dimension & Construction	IS 926 : 1985 CL-4	Upto 500 mm
		Workmanship & Finish (Def. test)	CL-5	Qualitative
		Performance Test	CL-6	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>24 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
<b>16</b>	<b>Gas Cartridges For Use In Fire Extinguishers</b>	General Requirements (Design & Shape)	IS 4947 : 2006 CL-3 & 5	Qualitative
		Capacity & Contents	CL-6	Upto 300 g
		Performance requirement test (HPT)	CL-7.1 & 7.2	Upto 650 kg/cm <sup>2</sup>
		Leakage test	CL-7.3	Qualitative
		Finish (Defectiveness test)	CL-8	Qualitative
		Body work (design & length)	CL - 5.6	Upto 5 m
		Cable winch (design & length)	CL-5.7	Upto 30 m
		Miscellaneous (structure of Bumper, size of ladder etc)	CL-5.9	Upto 3 m
		Locker (Shape & size)	CL-5.10	Upto 5 m
	Workmanship & Finish (Defectiveness test)	CL- 6	Qualitative	



<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>25 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
17.	<b>Couplings, double male and double female instantaneous pattern for fire fighting</b>	Dimension	IS 901 : 1988 CL-3.1	Upto 300 mm
		Hydraulic test requirement	CL-4.1	Upto 100 kg/cm <sup>2</sup>
		Workmanship and finish (Def. test)	CL-5.1	Qualitative
18.	<b>Suction Hose Coupling For Fire Fighting Purpose</b>	Shape & Dimension	IS 902 : 1992 CL-4.1	Upto 300 mm
		Construction couplings (Design & shape)	CL-5.1	Upto 300 mm
		Round threads for male coupling and nut	CL-5.2	Upto 25 mm
		Thread for locking ring and nut	CL-5.3	Major Dia-95 to 160 mm & Pitch Dia- 93 to 158 mm
		Workmanship and finish ( Def. test)	CL-7	Qualitative
		Hydraulic test	CL-8.1	Upto 100 kg/cm <sup>2</sup>

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>26 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
<b>19.</b>	<b>Fire Hose Delivery Couplings Branch Pipe Nozzles And Nozzle Spanner</b>	Delivery Hose Coupling	IS 903 : 1993 CL - 5.1	Qualitative
		Size and Dimension	CL - 5.3	Upto 100 mm
		Hydraulic test Requirement	CL - 5.4	Upto 100 kg/cm <sup>2</sup>
		Shape and Dimension	CL - 6.2	Upto 100 mm
		Hydraulic test Requirement	CL - 6.3	Upto 100 kg/cm <sup>2</sup>
		Size of Nozzle	CL - 7.2	Upto 100 mm
		Hydraulic test Requirement	CL - 7.3	Upto 100 kg/cm <sup>2</sup>
		Shape and Dimension of spanner	CL - 8.2	Upto 200 mm
<b>20.</b>	<b>2 way and 3 way suction collecting heads for fire fighting purposes</b>	Deflection test Requirement	CL - 8.4	Upto 100 kg
		Shape & Dimension	IS 904 : 1983 CL-3.1	Upto 200 mm
		Finish (Def. Test)	CL-4.1	Qualitative
		Hydraulic test	CL-5.1	Upto 100 kg/cm <sup>2</sup>

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>27 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
21.	<b>Delivery Breechings, Dividing And Collecting, Instantaneous Pattern, For Fire Fighting Purposes</b>	Types and Dimension	IS 905 : 1980 CL - 4.1 & 4.2	Upto 300 mm
		Finish (Def. Test)	CL - 5	Qualitative
		Hydraulic test	CL - 6.1	Upto 100 bar
22.	<b>Revolving Branch Pipe For Fire Fighting</b>	Dimension & Construction	IS 906 : 1988 CL - 4.1	Upto 300 mm
		Finish (Def.test)	CL - 5.0	Qualitative
		Performance requirements	CL - 6.1 & 6.2	Upto 100 kg/cm <sup>2</sup>
23.	<b>Fire Hydrant, Stand Post Type</b>	General Requirement (No. of sluice valve)	IS 908 : 1975 CL-2.1	Qualitative
		Workmanship and Finish (Def. test)	CL-4.1	Qualitative
		Hydrostatic test requirement	CL-5.1	Upto 100 bar
		Coating	CL-6.0	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>28 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
24.	<b>Hydrant Stand-Pipe For Fire Fighting</b>	Types and Dimensions	IS 5714 : 1981 CL - 4.1	Upto 100 mm
		Finish (Def.test)	CL - 5.1, 5.2, 5.3	Qualitative
		Hydrostatic Pressure test	CL - 6.1	Upto 100 bar
25.	<b>First –Aid Hose-Reel for Fire Fighting</b>	Dimension	IS 884 : 1985 CL-5.1	Upto 5 m
		Resistance to leakage	CL-5.2	Upto 100 kg/cm <sup>2</sup>
		Impact test	CL-5.3.1	Qualitative
		Load test	CL-5.3.2	Qualitative
26.	<b>Coupling, Branch Pipe, Nozzle Used In Hose Reel Tubing For Fire Fighting</b>	Workmanship and finish (defectiveness test)	IS 8090 : 1976 CL-4.1	Qualitative
		Branch pipe - Shape & dimension	CL-6.1	Upto 300 mm
		Branch Pipe - Construction (Design & Dimension)	CL-6.2	Upto 300 mm
		Branch Pipe - Hydraulic test requirement	CL-6.3	Upto 100 bar

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>29 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Coupling, Branch Pipe, Nozzle Used In Hose Reel Tubing For Fire Fighting</b>	Nozzles dimension	CL-7.1	Upto 300 mm
		Construction (Design)	CL - 7.2	Qualitative
		Hydraulic test requirement	CL - 7.3	Upto 100 bar
<b>27.</b>	<b>Branch Pipe, Universal, For Fire Fighting Purpose</b>		IS 2871 : 1983	
		Shape & Dimension	CL - 3	Upto 300 mm
		Workmanship and finish (Def. test)	CL - 4	Qualitative
		Hydraulic test	CL - 5	Upto 100 bar
<b>28.</b>	<b>Fire Hooks</b>		IS 927 : 1981	
		Handle (Length)	CL - 2.2	Upto 5 m
		Shape & dimensions	CL - 3	Upto 5m
		Workmanship & finish (Def. test)	CL - 4	Qualitative
		Performance test requirement (Load test)	CL - 5	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>30 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
<b>29</b>	<b>Fire Beaters</b>	Handle	IS 8096 : 1992 CL - 4.1	Qualitative
		Blade	CL - 4.2	Qualitative
		Assembling	CL - 5	Qualitative
		Workmanship (Def. test)	CL - 6	Qualitative
		Length	CL - 7.1	Upto 5 m
		Mass	CL - 7.2	Upto 10 kg
		Painting (Thickness)	CL - 7.3	Upto 2 mm
		Testing (Drop Test)	CL - 8	Qualitative
<b>30.</b>	<b>Fire Blanket</b>	Materials (thickness of as bestors cloth & stitching pattern)	IS 15381 : 2003 CL - 3	Upto 25 mm
		Manufacture (Design No. of pieces, stitching tension)	CL - 4	Qualitative
		Dimension & Tolerances	CL - 5	Upto 3 m
		Workmanship & Finish	CL - 6	Qualitative

**Laboratory** Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Mechanical Testing **Issue Date** 22.04.2014

**Certificate Number** T-2929 **Valid Until** 27.03.2016

**Last Amended on** 11.08.2014 **Page** 31 of 41

S.No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
31.	Galvanized Mild Steel Fire Bucket	Shape and Essential Dimension	IS 2546 : 1974 CL - 3	Upto 270 mm
		Body	CL - 4.1	Upto 10 mm
		Bottom	CL - 4.2	Upto 10 mm
		Ears	CL - 4.3	Upto 10 smm
		Top Handle	CL - 4.4	Upto 10 mm
		Bottom Handle	CL - 4.5	Upto 10 mm
		General (workmanship)	CL - 4.6	Qualitative
		Finishing	CL - 5.1	Qualitative
		Labeling(letter size)	CL - 5.3.1	Upto 80 mm
		Performance Requirements (Leakage test)	CL - 6	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>32 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

**I. PERFORMANCE TEST**

<b>1. Foam Concentrates for producing mechanical foam for Fire Fighting viz. AFFF, Protein Foam, Film Forming Fluoro Protein Foam &amp; Synthetic Foam</b>	Film formation	IS 4989 : 2006 Annex-H	Qualitative
	Expansion	Annex-J	Upto 20
	25% drainage time	Annex-J	Upto 10 minutes
	Fire control	Annex-K	Qualitative
	Fire Extinction	Annex-K	Qualitative
	Burn Back	Annex-K	Qualitative
	Sealability	Annex-K	Qualitative
<b>2. Multipurpose Aqueous Film Forming Foam Liquid Concentrates for Extinguishing Hydrocarbon &amp; Polar Solvent Fires</b>	Film formation	IS 4989 (Part 4): 2003 E-5 (Amendment No.1)	Qualitative
	Expansion	Annex-F	Upto 20
	25% drainage time	Annex-G	Upto 10 minutes
	Fire control time on n Heptane	Annex-J	Qualitative
	Fire Extinction time on n Heptane	Annex-J	Qualitative
	Burn Back on n-heptane	Annex-K	Qualitative
	Fire Performance test on Polar Solvent	Annex-H	Qualitative



<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>33 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

<b>3.</b>	<b>Aqueous Film Forming Foam (AFFF), Protein (P), Film Forming Fluoro Protein (FFFP), Fluoro Protein (FP) for both hydrocarbon &amp; Polar Fuel group</b>	25% drain time test using 2 GPM nozzle as per IS 4989: 2006  Expansion Test using 2 GPM nozzle as per IS 4989: 2006  Class-B Fire Test- Top Side discharge devices using 2 GPM nozzle as per IS 4989: 2006	UL - 162 : 1999 CL - 8.2 (8.2.1 to 8.2.7)  CL - 8.3 (8.3.1 to 8.3.2)  CL - 10 (10.1.1 to 10.5.6)	Upto 10 minutes  Upto 20  Qualitative
<b>4.</b>	<b>Dry Chemical Fire Extinguisher Capacity (Water capacity) ;- 4.5, 9.0, 14.0, 18.0, 36.0, 64.0, 125.0 l</b>	Fire Test	UL - 299 : 2009 CL - 24	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>34 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

<b>5.</b>	<b>Portable Fire Extinguishers – Performance &amp; construction</b>	Class A Test Fire Class B Test Fire Class D Test Fire	IS 15683 : 2006 CL-8.3 CL-8.4 CL-8.5	Qualitative (1A to 6A) Qualitative (8B to 233B) Qualitative
	<b>Capacity :-</b>			
	<b>a) Water base :</b>			
	<b>2,6,9 l</b>			
	<b>b) Foam :</b>			
	<b>2,4,6,9 l</b>			
	<b>c) Dry Powder :</b>			
	<b>1,2,4,6,9 l</b>			
	<b>d) CO<sub>2</sub> :</b>			
	<b>2,3,4.5 kg</b>			
	<b>e) Clean Agent</b>			
	<b>2,4, 6 kg</b>			
<b>6.</b>	<b>Fire fighting portable fire extinguishers- Performance and construction</b>	Class A Test Fire Class B Test Fire Class D Test fire Class F Test fire	ISO 7165 : 2009 CL-8.3 CL-8.4 CL-8.5 CL-8.7 & 8.8	Qualitative (1A to 20A) Qualitative (8B to 233B) Qualitative Qualitative (5F to 75F)
	<b>Capacity :-a) Water base ;</b>			
	<b>2,3,6,9 l</b>			
	<b>b) Powder ;</b>			
	<b>1,2,3,4,6,9,12 kg</b>			
	<b>c) CO<sub>2</sub> ;</b>			
	<b>2,5 kg</b>			
	<b>d) Clean agent :</b>			
	<b>1, 2, 4, 6 kg</b>			

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>35 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

<b>7.</b>	<b>Wheeled fire Extinguishers – Performance &amp; Construction</b> Capacity :-a)Water base ; 20,45,60, 125 l b)Powder ; 25,50,75 kg c)Clean agent ; 10,20,30,50 kg d) CO2 ; 4.5,6.5, 22.5, 45 kg	<b>Durability Test</b> <b>Class A Fire Test</b> <b>Class B Fire Test</b> <b>Class D Fire Test</b>	IS 16018 : 2012 CL-6.7 CL-7.2 CL-7.3 CL-7.4	Qualitative Qualitative (4A to 6A) Qualitative (8B to 233B) Qualitative
<b>8.</b>	<b>Portable Fire Extinguishers Part-7, Characteristics performance measurements &amp; test method</b> capacity:-Powder; 1,2,3,4,6,9,12kg Water base; 2,3,6,9 l CO2 ; 2,5 kg Halon ; 1,2,4,6 kg	<b>Class A Fire rating</b> <b>Class B Fire rating</b> <b>Class F Fire rating</b>	EN:3-7:2007-10 CL-15.2 CL-15.3 CL-15.4	Qualitative(5A to 55A) Qualitative(21B to 233B) Qualitative(5F to 25F)

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>36 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

<b>9.</b>	<b>Rating and Fire Testing of fire extinguishers</b>	Class - A extinguishers - Wood crib Fire Test	<b><u>UL -711: 2004</u></b> CL-7.1 &7.2	Qualitative (1A to 40A)
	<b>Capacity (Water capacity) :- 4.5,9.0,14.0, 18.0,36.0,64.0,125.0 l</b>	Class – B extinguishers – Flammable Liquid fire test	CL-8.1 &8.2	Qualitative (1B to 640B)
		Class – K extinguishers – Kitchen fire test (Vegetable Oil fire test)	CL-11.1 &11.2	Qualitative
<b>10.</b>	<b>Mobile Fire Extinguishers – Part-1:characteristics Performance and test methods</b>	Class A Fire Test object Class B Fire Test object	<b>DINEN1866-1 : 2007-10</b> CL-8.1 CL-8.2	Qualitative (5A to 55A) Qualitative (Type 1B to Type 4B)
	<b>Capacity:- Powder;- 25,50,100,150 kg</b>			
	<b>Water base ;- 20,25,45,50, 90,100,135, 150 l</b>			
	<b>CO2 ;- 10, 20, 30, 50 kg</b>			

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>37 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

<b>11.</b>	<b>Landing valves</b>	Flow test (Capacity of water flow in LPM)	IS 5290 : 1993 CL-7.3	Upto 1000 l/min
<b>12.</b>	<b>Functional requirements for water tender type 'a' for fire brigade use</b>	Body work & storage (design & dimension) Workmanship and finish (Defectiveness test)	IS 948 : 1983 CL-4.4.1 to4.4.5 CL-5.1 & 5.2	Upto 11 m Qualitative
<b>13.</b>	<b>Emergency (rescue) tender – functional requirements</b>	Design and Construction (Dimension) Body work (design) & length Cable winch (design) & length Miscellaneous (structure of Bumper, size of ladder etc) Locker (Shape & size) Workmanship & Finish (Defectiveness test)	IS 949 : 2012 CL - 5.1 CL - 5.6 CL - 5.7 CL - 5.9 CL - 5.10 CL - 6	Upto 5 m Upto 5 m Upto 30 m Upto 3 m Upto 5 m Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>38 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

<b>14. Functional requirements for water tender, type b for fire brigade use</b>	Water tank (capacity)	IS 950 : 2012 CL-5.3	Upto 7000 l
	Hose reels (HP, length)	CL-5.4	Upto 70 m
	Pump (capacity)		Upto 5000 LPM
	(i) a) Suction inlet	CL-5.5	Upto 300 mm
	b) Delivery valves	CL-5.6	Upto 5000 LPM
	(dimension, capacity)		
	Primer (capacity)	CL-5.7	Upto 7m
	Pipelines & Valve (Type & design)	CL-5.8	Qualitative
	Body work and stowage (design)	CL-5.11	Qualitative
	Miscellaneous (dimension & design)	CL-5.12	Upto 300 mm
	Provision for stowage of equipments (design)	CL-5.13	Qualitative
	Ladder Gallows (design)	CL-5.17	Qualitative
	Workmanship & Finish (Def. test)	CL-6.00	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>39 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

<b>15. Functional requirements for crash fire tender for air fields</b>	General(capacity)	IS 951 : 2003 CL-3	Upto 10,000 l
	Classification requirements (design & capacity)	CL-4	Upto 10,000 l
	Fuel system (capacity)	CL-7.3	Upto 200 l
	Exhaust system (design)	CL-7.4	Qualitative
	Vehicle drive	CL-7.6	Qualitative
	Suspension (design)	CL-7.7	Qualitative
	Rims, Types and Wheels (design)	CL-7.8	Qualitative
	Towing Connection (design)	CL-7.9	Qualitative
	Brakes (design)	CL-7.10	Qualitative
	Brakes, Air system (design)	CL-7.11	Qualitative
	Steering (design)	CL-7.12	Qualitative
	Cabin (design & size)	CL-7.13	Upto 5 m
	Body (design)	CL-7.15	Qualitative
	Fire fighting systems and agent (type)	CL-7.16	Qualitative
	Agents Pump and drives (design )	CL-7.17	Qualitative
	Pump drive	CL-7.18	Qualitative
	Suction and delivery connection (design)	CL-7.19	Qualitative

<b>Laboratory</b>	<b>Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri, Industrial Area, Phase – II, New Delhi</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Mechanical Testing</b>	<b>Issue Date</b>	<b>22.04.2014</b>
<b>Certificate Number</b>	<b>T-2929</b>	<b>Valid Until</b>	<b>27.03.2016</b>
<b>Last Amended on</b>	<b>11.08.2014</b>	<b>Page</b>	<b>40 of 41</b>

<b>S.No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
--------------	-----------------------------------	--------------------------------	--	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

	<b>Functional requirements for crash fire tender for air fields</b>	Piping, couplings and valves (design)	CL-7.20	Qualitative
		Water Tank (capacity)	CL-7.21	Upto 10000 l
		Foam Tank (capacity)	CL-7.22	Upto 1000l
		Hand lines (capacity)	CL-7.24	Upto 1000 LPM
		Foam quality (type & Quality)	CL-7.25	Qualitative
		Under truck nozzle (design & capacity)	CL-7.26	Qualitative
		Primer (capacity of Suction)	CL-7.27	Upto 7 m
		Dry chemical powder (type & Quantity)	CL-7.30	Upto 300 kg
<b>16.</b>	<b>First - Aid Hose-Reel for Fire Fighting</b>	Range and water flow rate in LPM	IS 884 : 1985 CL-5.4	Upto 1600 s & throw Upto 15 m
<b>17.</b>	<b>Foam making branch pipe</b>	General (Design & type) Performance requirements (Exp.) 25 % drainage time	IS 2097 : 1993 CL-2.1 & 3 CL-5.1 CL-5.2	Qualitative Upto 20  Upto 5 minutes



**Laboratory** Advance Fire Tec and Research Lab Private Limited, B-3 Mangolpuri,  
 Industrial Area, Phase – II, New Delhi  
**Accreditation Standard** ISO/IEC 17025: 2005  
**Discipline** Mechanical Testing **Issue Date** 22.04.2014  
**Certificate Number** T-2929 **Valid Until** 27.03.2016  
**Last Amended on** 11.08.2014 **Page** 41 of 41

S.No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
-------	-------------------------------	-------------------------	---	---

**AT SITE**

**Killa No.75/5/1, Kishora Road, Village-Kamaspur, Sonapat, Haryana**

18.	Nozzle for fire brigade use	Shape & Dimension	IS 952 : 1986	Upto 5 m
		Performance requirements	CL-3	Upto 900 ltre/min.
		Workmanship & finish	CL-4.1, 4.2 & 4.2.1	
		(Defectiveness test)	CL- 5	Qualitative

**-X-X-X-X-X-X-X-X-X-X-X-X-**