

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>1 of 15</b>

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
--------	----------------------------	-------------------------	---	--

**AT LABORATORY**

**I. TRANSFORMERS AND REACTORS**

<b>1. Power &amp; Distribution Transformers Single And Three Phase Transformers Single Phase Oil Filled Transformers (5 kVA to 3333 kVA, 36 kV) Three Phase Oil Filled Transformers (6.3 kVA to 20000 kVA, 36 kV) Dry Type Transformers (25 kVA to 8000 kVA, 36 kV)</b>	Insulation Resistance	IS 2026-1: (2011) IEC 60076-1: (2011) IS 11171: (1985) CEI EN 60076-1: (2015) IEEE C.57.12.90: (2010)	0.1 MΩ to 1 TΩ (At 500 V, 1 kV, 2.5 kV, 5 kV)
	Polarization Index And Absorption Index	CBIP Manual on Transformers: 2013, Section BB, Clause 3.5	0.1 MΩ to 1 TΩ (At 500 V, 1 kV, 2.5 kV, 5 kV)
	Voltage Ratio And Check of Phase Displacement	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) IEC 60076-11: (2004) CEI EN 60076-1: (2015) IEEE C.57.12.90: (2010)	Qualitative (Ratio 1 to Ratio 150)
	Polarity (For 1 Phase Only)	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) CEI EN 60076-1: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	Qualitative (All Transformers 5 kVA to 3333 kVA, 36 kV)
	Vector Group Verification (3 Phase Transformers Only)	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) CEI EN 60076-1: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	Qualitative

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>2 of 15</b>

<b>S. No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Power &amp; Distribution Transformers Single And Three Phase Transformers Single Phase Oil Filled Transformers (5 kVA to 3333 kVA, 36 kV) Three Phase Oil Filled Transformers (6.3 kVA to 20000 kVA, 36 kV) Dry Type Transformers (25 kVA to 8000 kVA, 36 kV)</b>	Winding Resistance	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) CEI EN 60076-1: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	0.1 mΩ to 300 Ω
		No Load Loss And No Load Current	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) CEI EN 60076-1: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	1 W to 20 kW 0.02 mA to 80 A
		Short-Circuit Impedance And Load Loss	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) CEI EN 60076-1: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	2 % to 15 % Impedance and 25 W to 110 kW load loss
		Separate Source Voltage Withstand Or Applied Voltage	IS 2026-3: (2009) IS 11171: (1985) IEC 60076-3: (2013) CEI EN 60076-3: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	3 kV to 100 kV
		Induced Over Voltage Withstand (Or) Induced Voltage Withstand	IS 2026-3: (2009) IS 11171: (1985) IEC 60076-3: (2013) CEI EN 60076-3: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010) IEEE C.57.12.20: (2011)	100 Hz, 125 Hz, 150 Hz , 200 Hz

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>3 of 15</b>

<b>S. No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Power &amp; Distribution Transformers Single And Three Phase Transformers Single Phase Oil Filled Transformers (5 kVA to 3333 kVA, 36 kV) Three Phase Oil Filled Transformers (6.3 kVA to 20000 kVA, 36 kV) Dry Type Transformers (25 kVA to 8000 kVA, 36 kV)</b>	Temperature Rise	IS 2026-2: (2010) IS 11171: (1985) IEC 60076-2: (2011) CEI EN 60076-2: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	5 °C to 150 °C
		Zero Sequence Impedance(S) On 3 Phase Transformers	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) CEI EN 60076-1: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	2 % to 15 %
		Sound Level	IS 2026-10: (2009) IS 11171: (1985) CEI EN 60076-1: (2015) IEC :60076-10: (2016) IEEE C.57.12.90: (2010)	30 dB to 80 dB All transformers 5 kVA to 20,000 kVA, 66 kV
		Unbalance Current Measurement (3 Phase Transformers Only)	CBIP Manual: 2013 Page. 56 Clause. 6.3	8 mA to 100A
		Vacuum (For Oil Filled Transformers Only)	CBIP Manual-2013:Section-C 10,Page 91 & 92 IS1180-1: (2014) IEC 60076-1: (2011)	250 mm of Hg to 760 mm of Hg
	Air Pressure (For Oil Filled Transformers Only)	CBIP Manual-2013:Section-C 10,Page 91 & 92 IS1180-1: (2014) IS 2026-1: (2011) IEC 60076-1: (2011)	0.2 kg/cm <sup>2</sup> to 2 kg/cm <sup>2</sup>	

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>4 of 15</b>

<b>S. No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Power &amp; Distribution Transformers Single And Three Phase Transformers Single Phase Oil Filled Transformers (5 kVA to 3333 kVA, 36 kV) Three Phase Oil Filled Transformers (6.3 kVA to 20000 kVA, 36 kV) Dry Type Transformers (25 kVA to 8000 kVA, 36 kV)</b>	Lightning Impulse Voltage Withstand	IS 2026-3: (2009) IS 11171: (1985) IEC 60076-3: (2013) CEI EN 60076-3: (2015) IEC 60076-11: (2004) IEEE C.57.12.90: (2010)	10 kVp to 250 kVp  All transformers 5 kVA to 2 MVA 36 kV Class
		Capacitance Windings-To-Earth And Between Windings & Dissipation Factor of The Insulation System Capacitances	IS 2026-1: (2011) IEC :60076-1: (2011) CEI EN 60076-1: (1998)	1000 PF to 0.25 $\mu$ F 0.1 % to 199.9 %
		Partial Discharge Measurement	IS: 11171: (1985) IEC 60076-11: (2004)	5 pC to 50,000 pC All transformers 5 kVA to 8,000 kVA, 33 kV
		On Load Tap Changers	IS 2026-1: (2011) IEC 60076-1: (2011)	Qualitative
		Permissible Flux Density And Over Fluxing	IS 1180-1: (2014)	At 110 % (or) 112.5 % of rated flux density
		Harmonics of No Load Current	IEC 60076-1: (2000) CEI EN 60076-1: (2015) IS 2026-1: (2011)	Order of harmonics: 1 <sup>st</sup> to 50 <sup>th</sup> order
		Magnetic Balance	CBIP Manual (Publication No:317)-2013: Section-J Cl 7.3	200 V to 1000 V
		Specific Core Loss	IS 3024: 2006 IS-649:1997	0.05 W/kg to 15 W/kg
		Accelerated Ageing	IS 3024: 2006 IS-649:1997	0.05 W/kg to 15 W/kg

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>5 of 15</b>

<b>S. No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Power &amp; Distribution Transformers Single And Three Phase Transformers Single Phase Oil Filled Transformers (5 kVA to 3333 kVA, 36 kV) Three Phase Oil Filled Transformers (6.3 kVA to 20000 kVA, 36 kV) Dry Type Transformers (25 kVA to 8000 kVA, 36 kV)</b>	Magnetic Polarization	IS 3024: 2006 IS-649:1997	0.5 A/m to 2 at 800 A/m field strength
		Permeability	IS 3024: 2006 IS-649:1997	600 to 40000 on all grades of CRGO samples
		Stacking Factor	IS 3024: 2006 IS-649:1997	92 % to 98 % on all grades of CRGO samples
		Ductility [Bend ]	IS 3024: 2006 IS-649:1997	85 mm to 320 mm width of all grades of CRGO samples
		Short Circuit Withstand	IS 2026-5: (2011) IS: 11171: (1985) CEI EN 60076-1: (1998) IEC 60076-5: (2006) IEC 60076-11: (2004) IEEE C.57.12.00: (2010) IEEE C.57.12.90: (2010)	0.3 kA to 8.5 kA for 2 s All Transformers 5 kVA to 100 kVA, 11 kV
<b>2.</b>	<b>EHV Power Transformers Upto 500 MVA, 420 kV Class</b>	D.C. Insulation Resistance Each Winding to Earth And Between Windings & Polarization Index	IS 2026-1: (2011) IEC 60076-1: (2011)	1 MΩ to 1 TΩ
		Voltage Ratio and Phase Displacement	IS 2026-1: (2011) IEC 60076-1: (2011)	1 to 100
		Polarity (1ø Transformers Only)	IS 2026-1: (2011) IEC 60076-1: (2011)	Qualitative

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>6 of 15</b>

<b>S. No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>EHV Power Transformers Upto 500 MVA, 420 kV Class</b>	Vector Group Verification (3 Ø Transformers Only)	IS 2026-1: (2011) IEC 60076-1: (2011) CBIP Manual-2013 Section- BB,Cl.No:3.2.2..2	200 V to 500 V
		Winding Resistance	IS 2026-1: (2011) IEC 60076-1: (2011)	500 μΩ to 5Ω
		No Load Loss And Current	IS 2026-1: (2011) IEC 60076-1: (2011)	1 kW to 300 kW 0.1 A to 200 A
		Short Circuit Impedance And Load Loss	IS 2026-1: (2011) IEC 60076-1: (2011)	1 kW to 1300 kW
		Separate Source Voltage Withstand Or Applied Voltage	IS 2026-3: (2009) IEC 60076-3: (2013)	25 kV to 500 kV
		Induced Over Voltage Withstand Or Induced Voltage Withstand	IS 2026-3: (2009) IEC 60076-3: (2013)	40 kV to 600 kV. Frequency range: at 175 Hz
		Partial Discharge Measurement (Acld, Acsd & Ivpd)	IS 2026-3: (2009) IEC 60076-3: (2013)	10 pC to 500 pC
		Temperature Rise	IS 2026-2: (2010) IEC 60076-2: (2011)	Temperature Scanner (10 °C to 120 °C)
		Zero Sequence Impedance (3 Ø Transformers Only)	IS 2026-1: (2011) IEC 60076-1: (2011)	5 % to 100 %
		Acoustic Noise Level	IS 2026-10: (2016) IEC 60076-10: (2016)	50 dB to 90 dB
	Harmonics of No-Load Current	IS 2026-1: (2011) IEC 60076-1: (1999)	Up to 50 <sup>th</sup> Harmonics 0.01 % of fundamental	

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>7 of 15</b>

<b>S. No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>EHV Power Transformers Upto 500 MVA, 420 kV Class</b>	Lighting Impulse Voltage Withstand (Or) Full Wave Lightning Impulse For The Line Terminals (Or) Chopped Wave Lightning Impulse On Line Terminals	IS 2026-3: (2009) IEC 60076-3: (2013)	35 kV <sub>p</sub> to 2100 kV <sub>p</sub> 450 kJ
		Switching Impulse Voltage Withstand (Or) Switching Impulse for Line Terminals	IS 2026-3: (2009) IEC 60076-3: (2013)	35 kV <sub>p</sub> to 1200 kV <sub>p</sub> 450 kJ
		Capacitances Windings-To-Earth And Between Windings And Measurement of Dissipation Factor (Tan Δ) of The Insulation System Capacitances	IS 2026-1: (2011) IEC 60076-1 : (2011) CBIP Manual of Transformers-2013 Section J, Clause. 6.9	100 pF to 30 nF for capacitance and Upto 199.0 % for Tan Delta
		Magnetic Balance	CBIP Manual of Transformers-2013, Section BB, Clause. 3.17	230 Volts and 415 Volts
		Magnetizing Current At Low Voltage	CBIP Manual of Transformers-2013, Section BB Clause. 3.23	0.1 mA to 1 A
		Power Taken By Fans And Liquid Pump Motors	IS 2026-1: (2011) IEC 60076-1: (2011)	100 W to 25 kW
		Sweep Frequency Response Analysis	IEC 60076-18: (2011)	20 Hz to 2 MHz
		On-Load Tap Changers	IS 2026-1: (2011) IEC 60076-1: (2011)	NA
		Check of Core to Frame Insulation For Liquid Immersed Transformers	IEC 60076-1: (2011) CBIP Manual on Transformers-2013, Section BB, Clause. 3.15	0.1 kV to 12 kV

**Laboratory** Testing Laboratories (Units: 03, 04, 09, 10, 11 & 15), Toshiba Transmission & Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Electrical Testing **Issue Date** 06.09.2016

**Certificate Number** T-3002 **Valid Until** 05.09.2018

**Last Amended on** - **Page** 8 of 15

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
<b>II. ELECTRICAL MATERIALS -LIQUID DIELECTRIC MATERIALS</b>				
1.	New Insulating Oil	Appearance	IS 335: (1993) IEC 60296: (2012)	Qualitative
		Density	IS 1448-16: (2014) ISO 3675: (1998)	0.8 g/cc to 0.85 g/cc 0.85 g/cc to 0.90 g/cc
		Kinematic Viscosity	IS 1448-25: (1976)	1cst to 100 cst
		Interfacial Tension	IS 6104: 1971 ISO 6295: 1983	0.003 N/m to 0.090 N/m
		Flash Point	IS 1448-21: (2012) ISO 2719: (2002)	RT-370°C
		Pour Point	IS 1448-10: (1970) ISO 3016: (1994)	(-)40 °C to (+)10 °C
		Neutralization Value.	IS 1448-2: (2007)	0.0028 mg KOH/g to 10 mg KOH
		Corrosive Sulphur	IS 335: (1993) Annexure B	Qualitative
		Electric Strength	IS 6792: (1992) IEC 60156: (1995)	20 kV to 100 kV
		Dielectric Dissipation Factor	IS 6262: (1971) IEC 60247: (2004)	0.0001 to 10
		Specific Resistance	IS 6103: (1971)	1 x 10 <sup>9</sup> Ω-cm to 1 x 10 <sup>18</sup> Ω-cm



**Laboratory** Testing Laboratories (Units: 03, 04, 09, 10, 11 & 15), Toshiba Transmission & Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Electrical Testing **Issue Date** 06.09.2016

**Certificate Number** T-3002 **Valid Until** 05.09.2018

**Last Amended on** - **Page** 9 of 15

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection		
	New Insulating Oil	Oxidation Stability	IS 335: (1993) Annexure C	0.0028 mg KOH/g to 10 mg KOH/g 0.001 % to 10 % by weight		
		Total Acidity				
		Total Sludge				
		Ageing Characteristics			IS 12177: (1987)	1 x 10 <sup>9</sup> to 1 x 10 <sup>18</sup>
		Specific Resistance@27°C				
		Specific Resistance @90°C				1 x 10 <sup>9</sup> to 1 x 10 <sup>18</sup>
		Dielectric Dissipation Factor@90°C				0.00008 to 10
		Total Acidity				0.0028 mg KOH/g to 10 mg KOH
2.	Mineral Insulating Oil	Total Sludge		0.001 % to 10 % by weight		
		Presence of Oxidation Inhibitor	IS 13631 Section-1: (1993)	Qualitative		
		Water Content	IS 13567: (1992) IEC:60814: (1997)	1 mg/kg to 5000 mg/kg		
		Appearance	IS 335: (1993) IEC 60296: (2012)	Qualitative		
		Density	IS 1448-16: (2014) ISO 3675: (1998)	0.8 g/cc to 0.85 g/cc 0.85 g/cc to 0.90 g/cc		
		Kinematic Viscosity	IS 1448-25: (1976)	1 cst to 100 cst		

**Laboratory**                      **Testing Laboratories (Units: 03, 04, 09, 10, 11 & 15), Toshiba Transmission & Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana**

**Accreditation Standard**      **ISO/IEC 17025: 2005**

**Discipline**                      **Electrical Testing**

**Issue Date**      **06.09.2016**

**Certificate Number**          **T-3002**

**Valid Until**      **05.09.2018**

**Last Amended on**          **-**

**Page**                      **10 of 15**

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
	<b>Mineral Insulating Oil</b>	Interfacial Tension	IS 6104: (1971) ISO 6295: (1983)	0.003 N/m to 0.090 N/m
		Flash Point	IS 1448-21: (2012) ISO:2719: (2002)	50 °C to 370 °C
		Pour Point	IS 1448-10: (1970) ISO 3016: (1994)	(-)-40°C to (+)10 °C
		Neutralization Value.	IS 1448-2: (2007)	0.0028 mg KOH/g to 10 mg KOH/g
		Electric Strength	IS 6792: (1992) IEC 60156: (1995)	20 kV to 100 kV
		Dielectric Dissipation Factor	IS 6262: (1971) IEC 60247: (2004)	0.0001 to 10
		Specific Resistance	IS 6103: (1971)	1 x 10 <sup>9</sup> Ω-cm to 1 x 10 <sup>18</sup> Ω-cm
		Oxidation Stability Total Acidity Total Sludge	IS 335: (1993) Annexure C	(0.0028 mg to 10 mg) KOH/g 0.001 % to 10 % by weight
		Water Content	IS 13567: (1992) IEC 60814: (1997)	1 mg/kg to 5000 mg/kg

**Prachi Kukreti**  
**Convenor**

**N. Venkateswaran**  
**Program Manager**

**Laboratory** Testing Laboratories (Units: 03, 04, 09, 10, 11 & 15), Toshiba Transmission & Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Electrical Testing **Issue Date** 06.09.2016

**Certificate Number** T-3002 **Valid Until** 05.09.2018

**Last Amended on** - **Page** 11 of 15

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
<b>III. CONDUCTORS</b>				
1.	<b>Enameled Round Copper Wire</b>	Dimensional Check	IS 13730-0-1, IEC 60317-0-1 IS 13730-0-2, IEC 60317-0-2 IS 13730-0-3, IEC 60317-0-3 IEC 60317-0-9, IS 7401-1 IS 13730-27, IS 6162-1 IS 6162-2	0.01 mm to 25 mm
	<b>Enameled Rectangular Copper Wire</b>	Measurement of Electrical Resistivity	IS 13778-5: 2012 Clause. 3 IEC 60851-5: 2008 Clause. 3	0 to 0.018 Ω-mm <sup>2</sup> /m
	<b>Enameled Round Alluminium Wire</b>	Elongation	IS 13778-3: 2012 Clause. 3 IEC 60851-3: 2009 Clause. 3	10 % to 50 %
	<b>Enameled Rectangular Alluminium Wire</b>	Springiness	IS 13778-3: 2012 Clause. 4 IEC 60851-3: 2009 Clause. 4	5 ° to 72 °
	<b>Paper Covered Round Copper Wire,</b>	Flexibility And Adherence	IS 13778-3: 2012 Clause. 5 IEC 60851-3: 2009 Clause. 5	Upto 20 %
	<b>Paper Covered Rectangular Copper Wire</b>	Heat Shock	IS 13778-6: 2011 Clause. 3 IEC 60851-6: 2012 Clause. 3	Upto 200 °C
	<b>Paper Covered Round Alluminium Wire</b>	Cut Through	IS 13778-6: 2011 Clause. 4 IEC 60851-6: 2012 Clause. 4	Qualitative
	<b>Paper Covered Aluminium Rectangular Wire</b>	BDV	IS 13778-5: 2012 Clause. 4 IEC 60851-5: 2008 Clause. 4	0.15 kV to 20 kV (AC)
		Peel / Jerk	IS 13778-3: 2012 Clause. 5 IEC 60851-3: 2009 Clause. 5	Upto 200 rpm
		Corner Radius	IS 13778-2: 2013 Clause. 3 IEC 60851-2: 2009 Clause. 3	0.50 mm to 1.0 mm
	Pin Hole (Continuity of Insulation)	IS 13778-5: 2012 Clause. 5 IEC 60851-5: 2008 Clause. 5	0 to 30 faults	

**Laboratory** Testing Laboratories (Units: 03, 04, 09, 10, 11 & 15), Toshiba Transmission & Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Electrical Testing **Issue Date** 06.09.2016

**Certificate Number** T-3002 **Valid Until** 05.09.2018

**Last Amended on** - **Page** 12 of 15

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
		Resistance to Abrasion	IS 13778-3: 2012 Clause. 6 IEC 60851-3: 2009 Clause. 6	3.0 N to 15.7 N
<b>IV.</b>	<b>SWITCHGEAR EQUIPMENT</b>			
<b>1.</b>	<b>Switchgear Products: Vacuum Circuit Breakers (12 kV to 36 kV) &amp; AC Metal-Enclosed Switchgear And Control Gear (12 kV)</b>	Dielectric On The Main Circuit	IEC 62271-100: (2012) IEC 62271-200: (2011) IS 13118: (1991)	1 kV to 90 kV rms
		Auxiliary And Control Circuits		0.01 kV to 5 kV rms
		Resistance of The Main Circuit		20 $\mu\Omega$ to 200 $\mu\Omega$ 10 A to 100 A
		Design And Visual Checks		Qualitative
		Mechanical Operating		Timing: 0.5 ms to 200 ms Travel: 0.5 mm to 50 mm velocity: 0.01 m/s to 2 m/s Coil voltage: 1 V to 300 V (AC& DC) M2 Class (10000 Operations)
<b>2.</b>	<b>Switchgear Products: Current Transformers (12 kV to 420 kV) 25a to 2400a Accuracy Class: 0.2 s</b>	Temperature-Rise		100 A to 1600 A
		Secondary Winding Resistance (Rct)	IEC 61869-2: (2012) IS 2705 (Part 1, 2, 3 & 4): 1992	0.5 $\Omega$ to 10 $\Omega$
		Rated Knee Point E.M.F. (Ek) and Exciting Current At Ek	IEC 61869-2: (2012) IS 2705 (Part 1 & 4): 1992	1 V to 5 kV, 1 mA to 10 A
		Inter-Turn Overvoltage	IEC 61869-2: (2012) IS 2705 (Part 1): 1992	0.05 kV to 5 kV, 0.01 A to 5 A

**Laboratory** Testing Laboratories (Units: 03, 04, 09, 10, 11 & 15), Toshiba Transmission & Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Electrical Testing **Issue Date** 06.09.2016

**Certificate Number** T-3002 **Valid Until** 05.09.2018

**Last Amended on** - **Page** 13 of 15

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
	<b>Switchgear Products: Current Transformers (12 kV to 420 kV) 25a to 2400a Accuracy Class: 0.2 s</b>	Power-Frequency Voltage Withstand	IEC 61869-1: (2007) IEC 61869-2: (2012) IS 2705 (Part 1): 1992	1 kV to 700 kVrms
		Partial Discharge Measurement	IEC 61869-1: (2007) IEC 61869-2: (2012) IS 2705 (Part 1): 1992	2 pC to 10000 pC
		Accuracy Ratio Error & Phase Displacement Instrument Security Factor Composite Error Measurement	IEC 61869-2: (2012) IS 2705 (Part 1, 2, 3 & 4): 1992	RE%: (±) 0.0001 % to 20 %, PE: (±) 0.01 min to 680 min. 1 mV to 5 kV, 1 mA to 10 A
		Verification of Markings	IEC 61869-1: (2007) IS 2705 (Part 1): 1992	Qualitative
		Measurement of Capacitance And Dielectric Dissipation Factor	IEC 61869-1: (2007) IEC 61869-2: (2012) IS 2705 (Part 1): 1992	Tan delta: 0.00001 to 1.0 Capacitance: 0.000001 µF to 0.065 µF
3.	<b>Voltage Transformers (12 kV to 245 kV) Burden:300 VA, Accuracy Class:0.2</b>	Induced AC Voltage & Power Frequency Voltage Withstand	IEC 61869-1: (2007) IEC 61869-3: (2011) IS 3156 (Part 1): 1992	3 kV to 500 kV, 125 Hz
		Partial Discharge Measurement	IEC:61869-1: (2007) IEC:61869-3: (2011) IS 3156 (Part 1): 1992	2 pC to 10000 pC
		Accuracy	IEC 61869-3: (2011) IS 3156 (Part 1, 2 & 3): 1992	RE%: (±)0.0001 % to 20 %, PE: (±) 0.01 min to 680 min.

<b>Laboratory</b>	<b>Testing Laboratories (Units: 03, 04, 09, 10, 11 &amp; 15), Toshiba Transmission &amp; Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana</b>		
<b>Accreditation Standard</b>	<b>ISO/IEC 17025: 2005</b>		
<b>Discipline</b>	<b>Electrical Testing</b>	<b>Issue Date</b>	<b>06.09.2016</b>
<b>Certificate Number</b>	<b>T-3002</b>	<b>Valid Until</b>	<b>05.09.2018</b>
<b>Last Amended on</b>	<b>-</b>	<b>Page</b>	<b>14 of 15</b>

<b>S. No.</b>	<b>Product / Material of Test</b>	<b>Specific Test Performed</b>	<b>Test Method Specification against which tests are performed</b>	<b>Range of Testing / Limits of Detection</b>
	<b>Voltage Transformers (12 kV to 245 kV) Burden:300 VA, Accuracy Class:0.2</b>	Verification of Markings	IEC 61869-1: (2007) IS 3156 (Part 1): 1992	Qualitative tests
		Capacitance And Dielectric Dissipation Factor	IEC 61869-1: (2007) IEC 61869-3: (2011)	0.00001 to 1.0 0.000001 $\mu$ F to 0.065 $\mu$ F
<b>4.</b>	<b>Switchgear Products: Condenser Bushings (52 kV to 245 kV)</b>	Dielectric Dissipation Factor (Tan $\Delta$ ) And Capacitance At Ambient Temperature	IEC 60137: 2008 IS 2099: 1986	0.00001 to 1.0 0.000001 $\mu$ F to 0.065 $\mu$ F
		Dry Power-Frequency Voltage Withstand	IEC 60137: 2008 IS 2099: 1986	105 kV to 700 kVrms
		Partial Discharge Quantity	IEC 60137: 2008 IS 2099: 1986	2 pC to 100000 pC
		Tap Insulation	IEC 60137: 2008 IS 2099: 1986	0.01 kV to 5 kVrms 0.000001 $\mu$ F to 0.26 $\mu$ F 0.00001 to 1.00
		Tightness On Liquid-Filled, Compound-Filled And Liquid-Insulated Bushings	IEC 60137: 2008 IS 2099: 1986	0.1 kg/cm <sup>2</sup> to 4 kg/cm <sup>2</sup>
		Visual Inspection and Dimensional Check	IEC 60137: 2008 IS 2099: 1986	Qualitative

**Laboratory** Testing Laboratories (Units: 03, 04, 09, 10, 11 & 15), Toshiba Transmission & Distribution Systems (India) Private Limited, Rudraram Village, Patancheru Mandal, Medak, Telangana

**Accreditation Standard** ISO/IEC 17025: 2005

**Discipline** Electrical Testing **Issue Date** 06.09.2016

**Certificate Number** T-3002 **Valid Until** 05.09.2018

**Last Amended on** - **Page** 15 of 15

S. No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
--------	----------------------------	-------------------------	---	--

**AT SITE**

**I. TRANSFORMERS AND REACTORS**

1.	Power & Distribution Transformers Power & Distribution Transformers Single And Three Phase Single Phase Oil Filled Transformers (5 kVA to 200 kVA, 36 kV) Three Phase Oil Filled & Dry Type Transformers (6.3 kVA to 1000 kVA, 36 kV)	Winding Resistance	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) IEC 60076-11: (2004)	0.5 mΩ to 500 Ω
		Insulation Resistance	IS 2026-1: (2011) IEC 60076-1: (2011) IS 11171: (1985)	0.1 MΩ to 1 TΩ (At 500 V, 1 kV, 2.5 kV & 5 kV) All Transformers
		Impedance And Load Loss	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) IEC 60076-11: (2004)	1 % to 10 % Impedance 1 W to 15 kW load loss
		No Load Loss And No Load Current	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) IEC 60076-11: (2004)	1 k W to 50 kW 0.01 mA and 40 A
		Ratio	IS 2026-1: (2011) IS 11171: (1985) IEC 60076-1: (2011) IEC 60076-11: (2004)	Qualitative (Ratio 1 to Ratio 150)

-X-X-X-X-X-X-X-X-X-X-X-X-