| S.No. Product / | Specific Test Performed | Test Method Specification | Range of Testing / | | |
|-----------------------|-------------------------|---|--------------------|--|--|
| Last Amended on | - | Page | e 1 of 1 | | |
| Certificate Number | T-3348 | Valid | Until 30.03.2017 | | |
| Discipline | Electrical Testing | Issue | e Date 31.03.2015 | | |
| Accreditation Standar | d ISO/IEC 17025: 2005 | | | | |
| Laboratory | Delhi Control Devices | Delhi Control Devices Pvt. Ltd., A-33, Sec-59, Noida, Uttar Pradesh | | | |

| 5.NO. | Material of Test | Specific Test Performed | against which tests are performed | Limits of Detection | | |
|-------|---|--|---|---|--|--|
| I. | ELECTRICAL INDICATING & RECORDING INSTRUMENTS | | | | | |
| 1. | Acceptance Test for Single Phase AC Static Watt Hour Meters Class 1 | Limits of Errors due to variation of current | IS 13779: 1999 (Amendment No.04 June, 2006) (Cl11.1) | 90V to 300 V, 10 mA to 100 A, 0.5 Lag to 0.5 Lead, 45 Hz to 55 Hz | | |
| | | Meter constant | (Cl. 12.15) | 45 112 to 55 112 | | |
| | | Starting condition | (Cl. 12.14) | | | |
| | | Test of Repeatability of Errors. | (Cl. 12.17) | | | |
| | | Test of No-Load Condition | (Cl. 12.13) | 90 V to 300 V 45 Hz to 55 Hz | | |
| | | Test of influence quality Voltage variation Frequency variation Influence of 10 % of third harmonic in current | IS 13779: 1999 (Amendment No.04 June, 2006) (Cl. 12.11) | 90 V to 300 V, 10 mA to 100 A, 0.5 Lag to 0.5 Lead, 45 Hz to 55 Hz | | |
| | | Test of power consumption. | (Cl. 12.7.1) | | | |
| | | Insulation test | (Cl. 12.7.6.4) | $200~\Omega$ to $1000~M\Omega$ | | |
| | | AC High Voltage Test | (Cl. 12.7.6.3) | 240 V to 4 kV | | |
| | | | | | | |