Laboratory Electrical Testing Laboratory of Jay Auto Components Ltd., Khasra

No. 39/14, 15/1, 17/1, Khandsa Road, Village-Mohammadpur Jharsa,

Post-Kherki, Dhaula, Distt. Gurgaon, Haryana

Accreditation Standard ISO/IEC 17025: 2005

Certificate Number TC-5701 (In lieu of T-3411) Page 1 of 1

Validity 24.05.2017 to 23.05.2019 Last Amended on --

SI.	Product / Material	Specific Test	Test Method Specification	Range of Testing /
	of Test	Performed	against which tests are	Limits of Detection
			performed	

ELECTRICAL TESTING

1.	Static Energy	AC High Voltage test	IS 13779	(Qualitative)
	Meter for Active		Cl.No. 12.7.6.3	Ùp to 4kV
	Energy Meter	Insulation Test	IS 13779	Up to 20MΩ
	(Single Phase	<u> </u>	Cl.No. 12.7.6.4	Up to 500 VDC
	Energy Meter	Test of limits of error	IS 13779	40V to 288V
	Class 1.0)		Cl.No. 11.1	10mA to 120A
				0.2W to 36kW
		Test of meter constant	IS 13779	40V to 288V
			Cl.No. 12.15	1mA to 120A
		Test of starting current	IS 13779	(Qualitative)
			Cl.No. 12.14	40V to 288V
				1mA to 500mA
		Test on No load	IS 13779	40V to 288V
		condition	Cl.No. 12.13	
		Test of repeatability of	IS 13779	40V to 288V
		errors	Cl.No. 12.17	1mA to 120A
				0.2W to 36kW
		<u> </u>	<u> </u>	PF : (-)0.5 Lag to 0.8 Lead
		Test of Power	IS 13779	40V to 290 V
		Consumption of tests	Cl.No. 12.7.1	0.15W to 20W
				1.45VA to 50VA
				5 mA to 60 A
				PF: (-)0.5Lag to 0.8 Lead

Sachin Tomar Convenor