Shri Krishna Laboratories and Power Services, #44, 6<sup>th</sup> Main, 8<sup>th</sup> Cross, Priyadarshini Colony, Gokul Road, Hubli, Karnataka Laboratory

**Accreditation Standard** ISO/IEC 17025: 2005

Page 1 of 1 **Certificate Number** TC-7068

Validity 22.03.2018 to 21.03.2020 Last Amended on --

SI.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are	Range of Testing / Limits of Detection
			performed	

## **ELECTRICAL TESTING**

I.	ELECTRICAL MAT	ERIALS – LIQUID DIELEC	TRIC MATERIALS	
1.	Transformer oil	Break Down Voltage	IS 6792	2 kV to 100 kV
		Tan Delta	IS 6262	0.0001 & above
		Resistivity	IS 6103	10 <sup>6</sup> -10 <sup>15</sup> Ohm-cm
		Moisture Content	IS 13567	1 mg/L & above
		Neutralization Number	IS 1448(Part-2)	0.0001mgKOH/gm & above
		Sludge	IS 1866	Nil to 2gm
		Interfacial tension	IS 6104	0 to 90 N/m
		Flash Point	IS 1448 (Part -21)	27°C to 360°C
		Dissolved gas analysis (DGA): Methane Ethanes Ethylene Acetylene Hydrogen Carbon Monoxide Carbon Dioxide	IS 9434 & IS 10593	> 1 mg/L

Alok Jain
Program Direct