

Laboratory **Shanthala Power Limited, Energy Meters Testing Laboratory,
Plot No. 18/2, Belligati Village, Post:Niralagi, TQ:Kundagol,
Dist:Dharwad, Karnataka**

Accreditation Standard **ISO/IEC 17025: 2005**

Certificate Number **TC-7790**

Page 1 of 3

Validity **30.08.2018 to 29.08.2020**

Last Amended on --

| Sl. | Product / Material of Test | Specific Test Performed | Test Method Specification against which tests are performed | Range of Testing / Limits of Detection |
|-----|----------------------------|-------------------------|---|--|
|-----|----------------------------|-------------------------|---|--|

ELECTRICAL TESTING

| I. | ELECTICAL INDICATING & RECORDING INSTRUMENTS | | | |
|----|--|----------------------------|---|--|
| 1. | AC Static Watt-hour Meters Class-1 & 2 1 Φ Meters | Insulation Resistance test | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 12.7.6.4 | 500 \pm 50V dc, >5M Ω |
| | | AC Voltage Test | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 12.7.6.3 | 0.1 kV to 5 kV |
| | | Limits of Error Test | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 11.1 of Table No.:15 | Voltage:Up to 64 V Current:0.25 A to 60 A PF:0.1 lag to UPF 0.1 lead to UPF |
| | | Test of Starting condition | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 12.14 (11.5- Table No.:19) | 1 mA to 200 A 1 V to 240 V |
| | | Meter Constant Test | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 12.15 (11.6) | Voltage:Up to 64 V Current:60 A PF:0.1 lag to UPF 0.1 lead to UPF |
| | | Test of No-load condition | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 12.13 | Upto 285 V 1 Φ |
| | | Power Consumption test | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 12.7.1 | Active power 1.5 W to 8 vA Apparent power 4.0 vA (CI-I) 2.5 vA (CI-II) |

Laboratory **Shanthala Power Limited, Energy Meters Testing Laboratory,
Plot No. 18/2, Belligati Village, Post:Niralagi, TQ:Kundagol,
Dist:Dharwad, Karnataka**

Accreditation Standard **ISO/IEC 17025: 2005**

Certificate Number **TC-7790**

Page 2 of 3

Validity **30.08.2018 to 29.08.2020**

Last Amended on --

| Sl. | Product / Material of Test | Specific Test Performed | Test Method Specification against which tests are performed | Range of Testing / Limits of Detection |
|------------|-----------------------------------|--------------------------------|--|---|
| | | Repeatability of Error | IS 13779:1999 (RA 2015) IEC 61036:2000 Clause 12.17 | Voltage:Up to 64V Current:0.25 A to 64 A PF:0.1 lag to UPF 0.1 lead to UPF |

Deepak Kumar Sharma
Convenor

Anuja Anand
Program Manager

Laboratory **Shanthala Power Limited, Energy Meters Testing Laboratory,
Plot No. 18/2, Belligati Village, Post:Niralagi, TQ:Kundagol,
Dist:Dharwad, Karnataka**

Accreditation Standard **ISO/IEC 17025: 2005**

Certificate Number **TC-7790**

Page 3 of 3

Validity **30.08.2018 to 29.08.2020**

Last Amended on --

| Sl. | Product / Material of Test | Specific Test Performed | Test Method Specification against which tests are performed | Range of Testing / Limits of Detection |
|-----|----------------------------|-------------------------|---|--|
|-----|----------------------------|-------------------------|---|--|

ELECTRICAL TESTING

| AT SITE | | | | |
|---------|---|--|--------------------------------|---|
| I. | ELECTICAL INDICATING & RECORDING INSTRUMENTS | | | |
| 1. | AC Static Watt-hour Meters | Limits of Error Test/ Accuracy Test | IS 15707:2006 Clause 12.3.2 | 30 V to 480 V 0.04 Amp to 12 Amp 45 Hz to 65 Hz, Class:0.05s Direct mode 30 V to 480 V 0.5 Amp to 100 Amp 45 Hz to 65 Hz Class:0.2s with Clamp |

Deepak Kumar Sharma
Convenor

Anuja Anand
Program Manager